



Squamish Fire Department

40439 Tantalus Rd, PO Box 839, Garibaldi Highlands, British Columbia , V0N 1T0

Ph: 604.898.9666 squamish.ca/fire

Gasoline Filling Station Fire Safety Plan Requirements

The BC Fire Code (2012) Section 2.8 requires gasoline fuelling stations to have a site specific **Fire Safety Plan (FSP)**.

Scope:

The FSP shall be site specific for the fuelling facility, retained on site in a binder clearly labelled "Fire Safety Plan" and contain information on the following:

- **Site Plan** – location of safety equipment, address of business, shut-offs, vent locations, additional hazards etc.
- **Emergency Procedures** – Emergency shutdown, Spill response, Evacuation, Muster station.
- **Testing of Fire Safety Equipment** - Standards, intervals, etc.
- **Use of Fire Safety Equipment** – Methods for the use of site specific Fire Safety Equipment.
- **Testing of Fuelling Equipment** – Standards, intervals, etc.
- **Training of staff** – Staff shall be certified with an approved and current fire safety course. Documentation to be retained on site in the FSP Binder.
- **Emergency Contacts** – List and provide phone numbers for designated emergency contact personnel for the business, spill response agencies, property owners, fire department, etc.

The Fire Safety Plan shall be submitted to Squamish Fire Rescue for review and approval prior to posting. All employees shall be familiar with the fire safety plan and its location.

Any questions should be directed to the Fire Prevention staff at Squamish Fire Rescue

(604)-898-9666